


SEE SHEET 1 FOR GAS CONDITIONING EQUIPMENT ASSIGNMENT

Recommended Regulators	
Item 15	Kimroy Fisher 627M or 627HM
	Mooney
Item 16	Kimroy Fisher 627 or 627H
	Mooney



DOMINION	
PROJECT NO.	111111
PRODUCTION STATION METER SET	111111
GENERAL ASSIGNMENT	111111
DATE	03/21/05
SCALE	1"=1'-0"
DRAWING PAGE	2 OF 2
DESIGNED BY	111111
CHECKED BY	111111
APPROVED BY	111111
DATE	03/21/05
PROJECT NO.	111111
PRODUCTION STATION METER SET	111111
GENERAL ASSIGNMENT	111111
DATE	03/21/05
SCALE	1"=1'-0"
DRAWING PAGE	2 OF 2
DESIGNED BY	111111
CHECKED BY	111111
APPROVED BY	111111
DATE	03/21/05

LEAK TEST AT 150 PSIG BEFORE INCREASING TO FINAL TEST PRESSURE

PRESSURE TESTING REQUIREMENTS	
FACILITY	PRODUCTION STATION METER SET
CLASS LOCATION	3
TEST MEDIUM	ARY/NITROGEN/WATER
TEST PRESSURE	1 Hour
MINIMUM TEST PRESSURE	270 PSIG
MAXIMUM TEST PRESSURE	400 PSIG
SAFETY	NOT REQUIRED

