

Gas Quality Quick Reference Guide	
Element	Allowable Quantity
BTU - Saturated	Minimum 980; Maximum 1100
Bacteria	None
Carbon Dioxide	Maximum 2%
Carbon Monoxide	Maximum 0.1% by volume
Combined Non-Hydrocarbons*	Maximum 4%*
Dust, Gums and Solid Matter	None
Free Flowing Water	Free of water and hydrocarbon liquids
Hydrogen Sulfide	Maximum 0.25 gr/100 cu ft or 4 ppm
Gasoline	Maximum 0.20 /gal/1000 cu ft
Nitrogen	Maximum 3%
Oxygen	Maximum 0.20% OR 2000 ppm
Temperature	Maximum 100°F
Total Sulfur	Maximum 10 gr/100 cu ft or 170 ppm
Water Vapor	Maximum 7 lbs./1mm cu ft

Notes

1. * The total combination, by volume, of carbon dioxide and nitrogen must not exceed 4%.
2. All producers are required to adhere to the above Guidelines unless otherwise explicitly specified in the executed agreement with Peoples.